

# RFP#16-028-20

## Building Access Control

### Addendum #1

Door requirement changes:

Courthouse front door (facing Hall Avenue) – door status only

Courthouse East exit (between Courthouse and Annex, Hall Avenue sidewalk) – door status only

ADRC – HHSD crossover hallway to outside (East exit door to Raymond Street) – door status only

HHSD – outside door (by generator and Houston Street) – Add reader and door status

HHSD – Adapt 1<sup>st</sup> & 2<sup>nd</sup> floor employee entrances – Add reader and door status

Jail exit door by chiller room – Add door status

Sheriff employee entrance – Move reader to outside door

Sheriff evidence room -- Dual authentication in / single out with status

Outside evidence room – door status only (check with Sheriff)

A141A – Admin. Investigation door – reader and status

Evidence room garage door – Dual authentication in / single out with status

IT room behind Sheriff administrative assistance – Dual authentication with status

IT room behind dispatch – Dual authentication plus status and hardware required

Integration of all ADA assisted doors

Door locks/hardware to remain if in good condition (Marinette County has final decision)

Door in ADRC has alarm button for emergency exit – button operation needs to be incorporated

Door hardware is required by IT room by jail administrator

Re-use as much of wiring as possible. Marinette County has final decision if wiring replacement is required.

Item to note – door behind jail administrator near jail entrance has reader on both sides