

**Request for Proposal #15-021-34**  
**UW Marinette Library Roof Replacement**  
**Addendum #2**  
**Posted 3/3/15**

- 1) Regarding roofing insulation system, due to specifications not being clear, it is requested that all vendors supply quotes per individual interpretation of the specifications. Marinette County is attempting to clarify the specifications and post by Friday, March 6<sup>th</sup>. In addition, it is requested that all vendor provide an option to provide a roofing replacement based upon their professional judgment and expertise. Items varying from, or interpreted, must be detailed.
- 2) Metal coping is required around the entire perimeter of the roof. This includes the areas where adjacent roofs merge and may already have membrane covering the stone coping.
- 3) Regarding the performance bond, it will be required to be a 100% performance bond executed by the selected contractor.