

Request for Proposal #15-021-34
UW Marinette Library Roof Replacement
Addendum #3
Posted 3/9/15

The coping metal and edge metal shall only be installed over the existing stone coping at the perimeter walls. Coping metal shall not be installed at the interior or intermediate walls. The interior or intermediate walls shall be wrapped with roof membrane and a termination bar shall be installed.

REVISIONS TO THE SPECIFICATION:

The revisions to the specifications below shall clarify the insulation system being proposed.

2.5 ROOF INSULATION

- A. General: Preformed roof insulation boards that comply with requirements and referenced standards, selected from manufacturer's standard sizes and of thicknesses indicated.
- B. Polyisocyanurate Board Insulation: ASTM C 1289, Type II, Basis of Design: [ENRGY 3](#)
 - 1. Provide insulation package with 1.5" start at drain location.
 - 2. Reaching a total height of 5.5" to match the existing assembly.

2.6 TAPERED INSULATION

- A. Tapered Insulation: ASTM C 1289, provide factory-tapered insulation boards fabricated to slope of 1/8 inch per 12 inches (1:96), unless otherwise indicated. Basis of Design: Tapered ENRGY 3