

ADDENDUM #1

RFP# 15-044-34 - IS SERVER ROOM AC UNIT

1. Provide option to interface new Liebert unit to the existing Liebert unit which will remain as back-up system.
2. Provide option to replace both air conditioning systems. Original scope is to replace existing Contempo unit and condensing unit. Option would be to also replace the existing Liebert unit and condensing unit. The operation of both units needs to work as a lead/lag operation to balance operational hours between both units. Must interface utilizing BackNET technology. Both units must tie into Metasys for monitoring and control. Replacement would need to be coordinated with Marinette County Information Services and Maintenance departments. Replacement schedule would need to provide for uninterrupted cooling for server room.
3. Marinette County has option to retain reclaimed refrigerant for use in other County units. Otherwise, vendor to dispose of used refrigerant according to all regulations.